

**October 2009
Intergovernmental Reviews
Thomas Jefferson Planning District Commission**

LOCAL

FY10 – 12 Keswick Utilities, Inc. application for modification of permit to release treated sewage wastewater

The Department of Environmental Quality proposes to modify the Keswick Utilities, Inc. permit to release treated sewage wastewater at a rate of 0.099 million gallons per day into Broadmoor Lake in Albemarle County in the Middle Rivanna River/Buck Island Creek watershed. The modification of the permit would remove limits and monitoring requirements for total recoverable copper at Outfall 004. No other changes are proposed. The permit and monitoring records have been requested but not received yet.

Public Comment Period: 30 days following first public notice issue date

FY10 – 13 Department of Environmental Quality Reissuance of VPDES Permit for The Twin Oaks Community

DEQ proposes to reissue the permit for The Twin Oaks Community Sewage Treatment Plant. The plant is permitted to release treated sewage wastewaters from a residential community at a rate of 0.01 million gallons per day into a water body. Sludge from the treatment process will be dried, stored onsite, and disposed of in the Louisa County landfill or sent to the Louisa Regional WWTP for disposal. The facility proposes to release the treated sewage into Polecat Creek in Louisa County, which is located in the South Anna River/Roundabout Creek watershed. The permit and monitoring records have been requested but not received yet. The permit includes limits for organic matter, solids, chlorine, bacteria, and pH. The DEQ representative explained the permit is a reissuance of a permit for a facility that has been in place for some time and no changes have been made that make it less stringent.

Public Comment Period: September 18, 2009 to 5:00 p.m. October 19, 2009